

Navajo Dam Domestic Water Consumers Inc, NM3536724  
4 Road 42670, Navajo Dam, NM 87419  
nddwu6308@gmail.com

To: NMED-DWB, email address

RE: Monthly Operating Report for October 2023

Dear Surface Water Rule Administrator:

The Navajo Dam Domestic Water Consumers Inc, submits their monthly operating report (MOR) for the month of October, 2023. During the month, we have the following to report:


Days of Production	31 days
Amount of Raw Water Pumped	865,000 gallons
Amount of Finished Water Produced	691,000 gallons
Billed water	gallons
Highest turbidity	.04 NTU
Percent turbidity below 0.3 NTU	100%
Lowest chlorine residual entering distribution	1.0 ppm
Lowest distribution residual	0.09 ppm
Lowest CT Ratio	1 (unitless)

During October 2023 we did not encounter operational and production issues.

Our treatment plant met all requirements of the Safe Drinking Water Act during the month of October 2023

I attest to the accuracy and completeness of the attached monthly operating report for October, 2023

Respectfully,



Teresa Garcia, NM11431, Water 4, March 2024

CC: Board members  
Administrative Contact